

BUREAU OF BROADCAST SERVICES  
4<sup>TH</sup> Floor, Media Center Building,  
Visayas Avenue, Quezon City

CANVASS FORM

Date: \_\_\_\_\_  
PR Number: 2024-05-0207

Gentlemen: Please quote your government price/s for the article/s listed hereunder:

Item No.	Qty	Unit	Articles	Approved Total ABC	Amount
1	1	Lot	<b>Airconditioner</b>	<b>P95,700.00</b>	
	1	unit	<b>3.0 TR Split Type Floor Mounted ACU</b> Delivery and Installation Included (1 Year Warranty) Specification: Cooling Capacity (kj/hr) – 39,035 Rated Power – 3,980 Watts Rated Current – 17.4 Amp. EER (kj/hW) – 9.81 Noise Level (low) – 50dB(A) Air Flow Volume (Hi/Med/Low) – 1,567 m <sup>3</sup> /h Pipe Size (Liquid/Gas) – 3/8" & 5/8" Volt/Hz/Phase – 230 Volts, 60 Hz, 1 phase Refrigerant – R410A Max Refrigerant Pipe Length – 30m  <b>Scope of Works Includes:</b> <ul style="list-style-type: none"><li>➤ Supply of labor and materials such as copper tubes, rubber insulation, THHN type electrical control wires circuit breaker, flexible orange for control (indoor), pvc pipe for drain line, and fabrication and installation of brackets</li><li>➤ Supply water-tight flexible conduit for outdoor unit electrical supply and controls</li><li>➤ Supply of consumable items such as Freon Gas, Nitrogen Gas, Oxy-acetylene, and welding materials</li><li>➤ Leak testing and vacuuming</li><li>➤ Technical supervision, start-up and commissioning</li><li>➤ Dismantling and Hauling of Existing AC Unit</li></ul> X-X Please email this form to: pbs.bbs.procurement@gmail.com or fax to (02)8920-4353  Ocular inspection of suppliers is required as part of their submission of quotation.	P95,700.00	

Please submit your quotation \_\_\_\_\_ days after receipt of this form.

Very truly yours,

JUDITH A. TRABALLO  
Canvasser

EMMANUEL CEDRIC M. ONTONG  
Chief, Procurement Service

The above price/s and /or quotation/s for the article/s  
you wish to purchase/repair is/are available within  
\_\_\_\_\_ days from the date of quotation.

AUTHORIZED SIGNATURE

Date quoted: \_\_\_\_\_

Price Valid For: \_\_\_\_\_

Terms: \_\_\_\_\_