

BUREAU OF BROADCAST SERVICES
4TH Floor, Media Center Building,
Visayas Avenue, Quezon City

CANVASS FORM

Date: _____

PR Number: 2025-04-0118

Gentlemen: Please quote your government price/s for the article/s listed hereunder:

Item No.	Qty	Unit	Articles	Approved Total ABC	Amount
1	1	unit	FM2 News Airconditioner 1.5HP Split Type Wall Mounted ACU Delivery and Installation Included (1 Year Warranty) Specification: Cooling Capacity (kj/hr) – 12,660 Rated Power – 1,095 Watts Rated Current – 7.16 Amp. EER (kj/hW) – 11.66 Noise Level (low) – 40.5 dB(A) Air Flow Volume (Hi)CHM – 2,300 Pipe Size (Liquid/Gas) – 1/4" & 1/2" Volt/Hz/Phase – 230 Volts, 60 Hz, 1 phase Refrigerant – R32 Max Refrigerant Pipe Length – 25m Scope of Works Includes: <ul style="list-style-type: none">➤ Supply of labor and materials such as copper tubes, rubber insulation, THHN type electrical control wires, circuit breaker, flexible orange for control (indoor), pvc pipe for drain line, and fabrication and installation of brackets➤ Supply water-tight flexible conduit for outdoor unit electrical supply and controls➤ Supply of consumable items such as Freon Gas, Nitrogen Gas, Oxy-acetylene, and welding materials➤ Leak testing and vacuuming➤ Technical supervision, start-up and commissioning➤ Dismantling and Hauling of Existing AC Unit	P60,000.00	
			X-X Please email this form to: bbs_propertyprocurement@yahoo.com or fax to (02)8920-4353 Ocular inspection of suppliers is required as part of their submission of quotation.		

Please submit your quotation _____ days after receipt of this form.

Very truly yours,

JUDITH A. TRABALLO

Canvasser

EMMANUEL CEDRIC M. ONTONG

Chief, Procurement Service

The above price/s and /or quotation/s for the article/s
you wish to purchase/repair is/are available within
_____ days from the date of quotation.

AUTHORIZED SIGNATURE

Date quoted: _____

Price Valid For: _____

Terms: _____